Isolated output generator set

Normal Supply

N   L1

Metering device

Main Active and Neutral disconnected and made safe

Plug coupler

GENERATING SET

MAIN SWITCHBOARD

M

Main Switch

MEN Removed

N

Additional RCD installed at main switchboard

E

Additional E-N link

EE

E   N   L1

To load via protection devices